

GLOBAL JOURNAL OF RESEARCHES IN ENGINEERING CIVIL AND STRUCTURAL ENGINEERING Volume 13 Issue 1 Version 1.0 Year 2013 Type: Double Blind Peer Reviewed International Research Journal Publisher: Global Journals Inc. (USA) Online ISSN: 2249-4596 & Print ISSN: 0975-5861

Rooftop Rain Water Harvesting for Groundwater Recharge in an Educational Complex

By Dr. Arun Kumar Dwivedi, Virendra B. Patil & Amol B. Karankal

S.S.V.P.S.B.S.Deore College of Engineering, Dhule (MS) India

Abstract - The rainwater harvesting locally collects and stores rainfall through different technologies, for future use to meet the demands of human consumption or human activities. However, rainwater harvesting has much wider perspectives, in particular, if it is considered in relation to its role in supporting ecosystem goods and services.

An integrated planning for Rooftop Rain Water Harvesting system for different institutes in the premises an educational complex is done. The main objectives of the study are to estimate the rooftop rain water harvesting potential of all buildings, planning and designing the rooftop rain water harvesting system, the conveyance system and the groundwater recharge system. The cost estimation of different components of roof top rain water harvesting project for each zone is done. The annual equivalent capital cost is estimated with and without the cost of ground water recharge structure. The unit cost of water is high as compared to the market price of water. However, the environmental benefits of the ground water recharging with good quality water justifies such projects.

Keywords : cost of water, groundwater recharge structure, rain water harvesting, rooftop rain water.

GJRE Classification : FOR Code : 090508, 090599



Strictly as per the compliance and regulations of :



© 2013. Dr. Arun Kumar Dwivedi, Virendra B. Patil & Amol B. Karankal. This is a research/review paper, distributed under the terms of the Creative Commons Attribution-Noncommercial 3.0 Unported License http://creativecommons.org/licenses/by-nc/3.0/), permitting all non commercial use, distribution, and reproduction in any medium, provided the original work is properly cited.

Rooftop Rain Water Harvesting for Groundwater Recharge in an Educational Complex

Dr. Arun Kumar Dwivedi ^a, Virendra B. Patil ^o & Amol B. Karankal ^p

Abstract - The rainwater harvesting locally collects and stores rainfall through different technologies, for future use to meet the demands of human consumption or human activities. However, rainwater harvesting has much wider perspectives, in particular, if it is considered in relation to its role in supporting ecosystem goods and services.

An integrated planning for Rooftop Rain Water Harvesting system for different institutes in the premises an educational complex is done. The main objectives of the study are to estimate the rooftop rain water harvesting potential of all buildings, planning and designing the rooftop rain water harvesting system, the conveyance system and the groundwater recharge system. The cost estimation of different components of roof top rain water harvesting project for each zone is done. The annual equivalent capital cost is estimated with and without the cost of ground water recharge structure. The unit cost of water is high as compared to the market price of water. However, the environmental benefits of the ground water recharging with good quality water justifies such projects.

Keywords : cost of water, groundwater recharge structure, rain water harvesting, rooftop rain water.

I. INTRODUCTION

a) Concept of Rain Water Harvesting

he rainwater harvesting consists of a wide range of technologies used to collect, store and provide water with the particular aim of meeting demand for water by humans and/or human activities, which is explained schematically in Figure-1. These technologies can be divided into two main areas depending on source of water collected; namely, the in situ and the ex situ types of rainwater harvesting, respectively.




Figure 1 : "Schematic Diagram showing the rainwater harvesting technologies based on source of water and water storage type" [UNEP(2009)]

b) Need For Rainwater Harvesting

Due to over population and higher usage levels of water the surface sources are being over stressed which has led to boring of tube wells at individual as well as at local government's level. The replenishment of ground water (GW) is drastically reduced due to paving of open areas. Indiscriminate exploitation of GW results in lowering of ground water table (GWT) rendering many bore-wells dry. To overcome this situation bore wells are drilled to greater depths. This further lowers the GWT and in some areas this leads to higher concentration of hazardous chemicals such as fluorides, nitrates and arsenic. In coastal areas, over exploitation of GW results in seawater intrusion thereby rendering GW bodies' saline. In rural areas also, government policies on subsidized power supply for agricultural pumps and piped water supply through bore wells are resulting into decline in GWT. The solution to all these problems is to replenish GW bodies with rainwater by manmade means.

Author a : Professor & Head, Department of Civil Engineering, S.S.V.P.S.B.S.Deore College of Engineering, Dhule (MS) India 424 005 E-mail : akd321@gmail.com

Author σ : Lecturer, Department of Civil Engineering, Government Polytechnic, Deopur, Dhule (MS) 424 005.

E-mail : patilvaibhav29@rediffmail.com Author p: Assistant Professor, Department of Civil Engineering, SSVPS BSD College of Engineeering, Deopur, Dhule (MS) 424 005.

E-mail : amolprabha@gmail.com

c) Indian Scenario: Rain Water Harvesting

The annual precipitation in India is estimated on an average 1100 mm. Although its distribution in space and time is highly variable, most of it is allowed to go waste as run-off water into the sea through the river system. The Government of India (Gol) is also promoting rainwater harvesting through watershed management programme, artificial recharge of GW and roof top rain water harvesting (RRWH) under various schemes. The main function of the urban local bodies is to guide the development according to the master plan prepared by the town & country planning departments and to provide and maintain the services like water supply, sanitation and transportation. The major flaw in these planning processes is that the building bye-laws and development charges do not encourage citizens to adopt RRWH and other measures to conserve the water. Also as water is being supplied at greatly subsidized rates, cost of water is between Rs 8.10 to Rs 6.10 per Kilo-liter at 1998-1999 prices while it is supplied at less than Rs 2.00 per Kilo-liter [Gol (2004)], by the urban local bodies so people are not encouraged to adopt the rain water harvesting which in turn is depleting the precious available water resources resulting in shortage of water in the urban areas. To overcome these problems there is a need to adopt water sensitive development controls as part of the building bye-laws in the master plan of the urban area itself. [Chakrabarti (2000)]

II. DESCRIPTION OF PROJECT AREA

a) Location

The Dhule town is located at latitude 21°10' and longitude 75°20', lying 57 km. north of Chalisgaon Bombay-Nagpur route of the central railway. The SSVP Sanstha is rendering the valuable services in the field of education for the people living in the Dhule town district, for last 104 years. The main campus of the SSVP Sanstha is located in Vidyanagari area of Dhule town. The campus includes the Science College, Arts College and Commerce College offering secondary and post secondary education along with an engineering college, polytechnic since 1983 and a School, since 2007. The area of these five institutes is clearly demarcated for educational activities; however there is lot of area which shared for practical purposes. The is beina administrative and educational working of all these five institutions is independent.

b) Necessity of Project

The water resources and the drainage system in the premises of these five institutes are shared. The gross area of the premises is 77,700 sqm, out of which 37 numbers of buildings in the premises constitutes 24938 sqm roof top areas. In present situation the rainwater from this huge roof top area is drained out of campus to nearby stream as overland flow and the guided flow through existing drainage network at some places. The overland flow leads to the erosion of soil from unpaved area in premises and chocking of the existing drainage system due to silting. This huge roof top area, if used for RWH, has immense potential for GW recharging. This will result in rise in GWT which in turn will increase the yield of the open dug wells and also the duration of their services. The benefits of the rise in GWT will be not being limited to the SSVPS premises; the nearby area will also be benefited from it. It will be an added advantage as discharge of institute's social responsibility. The GW recharge will also dilute the poor quality water percolated in the GW throughout the year from the two number of unlined streams (Nalas), carrying the waste water discharge from residential area located on north and west side of the residential area. The success chronicle of the proposed RWH project will motivate the other institutes, premises and big housing projects to adopt such installation to make the better environment.

III. Methodology for Planning & Design


a) Assumptions

The following are the assumptions; which are made in this proposed RRWH project-

- The rainfall intensity is taken as 50 mm per hour with the help of map, instead of actual applicable for Dhule region.
- The life of the RRWH system is considered as 40 years & the annual rate of interest is taken as 4% for calculating the annual equivalent cost (AEC) of the system.
- It is assumed that 40% of quantity of water which is recharged in ground is utilizable during lean period.

b) Buildings and Rooftop Area

An integrated planning for RRWH system for all five institutes is proposed. The entire area is divided in six zones, each having individual ground water recharge structure (GWRS). These six zones are shown in Figure - 2. All the buildings in premises are coded showing the institute's to which they belong and the number of building.



North Point school, Engineering College, Polytechnic, Science College and Arts and Commerce College respectively, along with the number of particular building. The two codes for a building mean that the building is shared by two respective institutes. The area of each building in different zones and their height are given in Table-1. These zones are planned by considering the elevation of GWRS with respect to the elevation of buildings in such a way that the harvested rain water from rooftop will reach to it under gravity through underground conveyance system. All the major buildings are divided into two or more parts depending upon their rooftop area and zones.

The codes of buildings are A, B, C, D & E for

Figure 2 : "Boundaries & Buildings in Six Zones for RRWH"

Table 1 :	"Doofton	Araa	Ctatiatian	Zana	Minon"
Table L.	ROOIIOD	Area	Statistics -	- Zone	vvise

Sr	ZONE	Code	Effective Area (Sqm)	Ht (m)	Туре	Sr	ZONE	Code	Effective Area (Sqm)	Ht (m)	Туре
1		A-1	184.87	7.2	SR	1		C-9	684.00	9.4	FR
2		A-2	178.50	2.7	SR	2		BC-10	1800.00	3.4	SR
3		A-3	2549.00	9.7	FR	3		B-11	1500.00	9.4	FR
4	ZONE-I	A4	636.00	3.4	FR	4	ZONE-IV	DE-6	600.00	6.4	FR
5	NO ₂	BC-1	106.32	6.4	FR	5	NO	D-5	330.00	6.4	FR
6		BC-2-1	468.58	9.8	FR	6		D-3	300.00	6.4	FR
7		DE-14	581.10	3.4	FR	7		D-4	300.00	6.4	FR
		SUM	4704.37					SUM	5514.00		
1		BC-2-2	365.64	9.8	FR	1		DE-17	258.00	6.4	FR
2		BC-3	587.57	9.4	SR	2		DE-16	330.00	6.4	FR
3	☴	B-4	736.15	9.4	SR	3		BC-12	105.00	6.4	FR
4	ZONE-II	B-5-1	2009.40	9.4	SR	4	~	BC-13	420.00	6.4	FR
5	ž	BC-15	316.80	2.7	SR	5	ZONE-V	BC-14	565.00	6.4	FR
6		DE-15	561.56	6.7	FR	6	NO ₂	DE-18	400.00	3.0	FR
		SUM	4577.12			7		DE-7-1	432.00	6.4	FR
1		B-5-2	1811.95	9.4	FR	8		D1	504.00	6.4	FR
2	_	BC-6	699.61	6.4	FR	9		D2	432.00	6.4	FR
3	ZONE-III	C-7-1	581.10	9.4	FR			SUM	3014.00		
4	NO ₂	C-7-2	741.32	9.4	FR	1		D-7-2	324.00	6.4	FR
5	N	C-8	620.34	9.4	SR	2		E-8	444.00	6.4	FR
		SUM	4454.32			3	_	E-9	444.00	3.2	FR
1		C-9	684.00	9.4	FR	4	ZONE-VI	DE-10	540.00	6.4	SR
2		BC-10	1800.00	3.4	SR	5	l õ	E-11	109.20	6.4	FR
3	>	B-11	1500.00	9.4	FR	6		DE-12	158.40	6.4	SR
4	ZONE-IV	DE-6	600.00	6.4	FR	7	1	E-13	544.50	6.4	FR
5	NO ^N	D-5	330.00	6.4	FR		F	SUM	2564.10		
6	IN I	D-3	300.00	6.4	FR		GRAN	D SUM	24938.00		
7		D-4	300.00	6.4	FR		•				
		SUM	5514.00								



c) Design Steps

The methodology for the planning and designing of RRWH system in each zone is explained in following steps;

- The route of RCC pipe below ground is finalized with the location of intake chambers to collect the harvested water from the different buildings of zone and to discharge it in GWRS.
- The area of each building in the zone is calculated and the planning for horizontal drain pipe on wall (HPW) or gutter at the edge of sloping roof (HGW) and vertical drain pipe on wall (VPW) is done in such a way that the VPW will discharge into one or two intake chambers depending upon the size of rooftop and location of chamber.
- In case of sloping roof the area of rooftop is increased by 20% for pitch more than 25° and 10% for less than 25°. The increased area is taken for calculation purpose.
- The HPW, HGW and VPW are designed as per norms as discussed. The rate of flow of each VPW discharging into different intake chamber is calculated.
- The RCC pipes below ground are designed for the corresponding discharge and available ground slope. The size of intake chamber is selected on the basis of available ground slope. In case of flatter slope the intake chamber of higher size may be selected.
- The open dug well is the most suitable GWRS option in the area. An open dug well of 6.0 m

diameter with horizontal bores of 115 mm diameter, 6 Nos. of length 30 m each are proposed.

d) Cost Estimation

The cost estimation of different components of RRWH project for each zone is done on the basis of District Schedule of Rates (DSR) of Maharashtra Jeevan Pradhikaran (MJP) for year 2010-11. The cost of semicircular gutters is considered as 67% cost of pipe of same size. The cost of minor fittings in PVC gutters and pipes are taken as 5% of the cost of same. The correct alignment and proper fitting of pipes and gutters in building is essential to avoid malfunctioning of the system and hence a special provision of 10% cost of pipes and gutter is kept for this purpose. The cost estimation of special structures, i.e. intake chamber and chamber with vent pipe is done separately and the same cost is taken. The life of the RRWH system is considered as 40 years and the annual rate of interest is taken as 4%, which is normally the interest of soft loan by various financial institutions for the purpose of calculation of annual cost of the project.

e) Sample Calculations for Zone : I

The list of buildings and their rooftop type and area is given in Table – 1. The total effective rooftop area in the zone is 4704.37 sqm. The average annual monsoon rainfall with 60% probability is 494.94 mm and is considered for calculating the RRWH volume. The planning for route of underground drainage system is shown in Figure -3, which also shows the ground RLs and the chainage of various intake chambers.




Figure 3 : Conveyance System below Ground for Zone-I

The PVC gutter for sloping roof i.e. HGW, PVC drain pipes on wall i.e. HPW and VPW are designed for all seven buildings in zone-I. The detailed are shown in Table-A.1 attached in appendix.

After planning and designing the RRWH system for all buildings, the rainwater discharge at each intake chamber is summed up and the size of underground pipe line system is calculated. The detailed calculations for the sizes of the underground reinforced cement concrete (RCC) pipes are shown in Table – A.2. The chamber with vent pipe are proposed at an average distance of 30 m or at the places of change in direction. The height of the intake pipe in intake chamber is taken as per the availability of ground slope to avoid the deep excavation. The abstract of estimate for RRWH system for zone-I is shown in Table – A.3. The GWRS is open dug well of 6.0 m diameter, 15 m deep and 30 m x 6 Nos of horizontal bores of 115 mm size. The AEC is estimated with and without the cost of GWRS.

IV. Conclusions

a) Cost Analysis

The total capital cost and its breakdown such as cost of pipes in buildings, conveyance system below GL and the cost of GWRS for all the six zones are shown in Figure - 4.




Figure 4 : Cost Breakdown of RRWH System in All Six Zones"

The unit cost of water with and without GWRS for 100% & 40 % utilizable quantity is shown in Figure -5.





Figure 5 : Unit Cost in All Six Zones



The AEC versus the RRWH potential of all six zones is shown in Figure 6.

Figure 6 : Annual equated cost versus Annual GW Recharge

The split of costs in % of gross cost of different elements of RRWH system i.e. pipes in buildings, pipes below ground and ground water recharge structures for whole premises is shown in Figure-7.




Figure 7 : % of Cost of Different Elements w.r.t. Gross Cost

b) Comments

The 40% utilization of recharged water is taken as a real life situation. The unit cost of recharged GW as calculated for the two scenarios, i.e. by considering the 100% water utilizable and second only 40% water is utilizable. In both the cases the cost is higher as compared to the market price of water. However, the environmental benefits of the ground water recharging with good quality water justifies such projects. It is evident from Figure -7, that 50% is the cost of GWRS. These structures are not meant only for recharging purpose. These may be used the ground water resource structure, to tap the recharged water. Hence, the full cost of these structures on the part of the RRWH system cannot be justified.

c) Future Scope

There is enough quantity of rain water, which can harvested from the play grounds, paved and semi-

paved circulation area and the garden area of the institute premises. These areas are around 3 – 4 times the rooftop area in the institute's premises. In the case study of SSVPS premises, which is presented here, the rooftop area is around 1/3rd of the gross area. If the RW from remaining area is harvested for GW recharge, through the proposed GWRS, the unit cost will have steep fall and the project may become financially more viable. Thus, the micro-level study of RWH from the remaining area of premises along with the water requirement of the premises may add new dimension to such project.

References Références Referencias

- 1. BIS (1742-1983), "Code of Practice for Building Drainage", Reaffirmed in 1996, Bureau of Indian Standard, Manak Bhavan, 9, Bahadur Shah Jafar Narg, New Delhi, 110 002, 1996.
- CGWB (1999), "Activities and Achievements of Central Ground Water Board on Rain Water Harvesting and Artificial Recharge", Central Ground Water Board, Ministry of Water Resources, Government of India, New Delhi, 1999.
- Garg (2006), Santosh Kumar Garg, "Sewage Disposal & Air Pollution Engineering", 18th Edition, Khanna Publishers, 2-B, Nath Market, Nai Sadak, Delhi-110 006, 2006.
- Gould et al (1999), Gould, John and Nissen-Petersen, Erik, "Rainwater Catchment Systems for Domestic Security", London, UK, Intermediate Technology Publications (ISBN 1853394564), 1999.
- Jacob (2008), "Rooftop Rainwater Harvesting for Rural Schools in Karnataka – Experiences", Solution Exchange for the Water Community Consolidated Reply Query : Compiled by Nitya Jacob, Resource Person and Ramya Gopalan, Research Associate, 9 May 2008.

- Jebamalar and Ravikumar (2011), A. Jebamalar and G. Ravikumar, "A comparative analysis of hydrologic responses to rainwater harvesting – A case study", Indian Journal of Science and Technology, Vol. 4 No. 1 (Jan 2011) ISSN: 0974-6846, pp : 34-39.
- Khare, Ojha and Srivatsava (2004), Deepak Khare, Ramakand, Ojha and Srivatsava RK, "Impact assessment of rainwater harvesting on ground water quality at Indore and Dewas, India", Journal of Indian Water Works Association, Volume-36(2), pp : 123-128.
- MOWR (2002), "Thirty Fourth Report Ministry of Water Resources Demands For Grants 2002 – 2003", Ministry of Water Resources Government of India, New Delhi, 2002.
- Patil (1999), Subhash M. Patil, "Plumbing Engineering – Theory, Design & Practice)", Revised & Enlarged Edition, Seema Publication, A2-9/003, Nirmal Society, Gokul Dham, Goregaon (E), Mumbai, 400 063, 1999.
- Sharma and Jain (1997), Sharma SK and Jain SK, "Ground water recharge through roof top rain water harvesting in urban habitation", International Conference on Management of Drinking Water Resources", 1997, pp :60.
- 11. UNEP (2009), "Rainwater Harvesting : A Lifeline For Human Well-Being", A report prepared for UNEP by Stockholm Environment Institute, Division of Environmental Policy Implementation United Nations Environment Programme (UNEP), P.O. Box 30552, Nairobi, Kenya, 2009.
- 12. Wong (2011), Jason J. Wong, "Optimizing Rainwater Harvesting Installation in Kashongi, Uganda: Sustainable Rural Water Supply, Collective Action and Institutions", Graduate Thesis, Duke University Durham, North Carolina, 2011.

1			A-1	: SR						
	F	Plan Area	A (m ²)	184.87	E	Effective Area A _{eff} (m ²)				
	Annua	I RRWH F	Potential (kL)	109.80	Total Di	scharge from Root	ftop (LPS)	3.08		
	Design of Rainwater Collection System on Wall/Roof									
	From	То	L (m)	CA (m ²)	Q (LPS)	Size (mm ²)	Dia (mm)	TYPE		
	1	2	13.00	110.92	1.54	5546.10	160.00	HG		
	3	4	13.00	110.92	1.54	5546.10	160.00	HG		
	4	5	13.00	110.92	1.54	5546.10	110.00	HPW		
	4	IC-1	7.20	221.84	3.08	5546.10	110.00	VPW		
2			Building	Code & Roof	Туре		A-2	: SR		
	F	Plan Area	A (m²)	178.50	E	Effective Area A _{eff} (r	m²)	214.20		
	Annua	I RRWH F	Potential (kL)	106.02	Total Di	scharge from Root	top (LPS)	2.98		
			Desig	n of Rainwate	r Collection S	System on Wall/Roo	of			
	From	То	L (m)	CA (m ²)	Q (LPS)	Size (mm²)	Dia (mm)	TYPE		
	1	2	17.00	107.10	1.49	5355.00	160.00	HG		
	3	4	17.00	107.10	1.49	5355.00	160.00	HG		
	4	5	11.00	107.10	1.49	5355.00	110.00	HPW		
	4	IC-2	2.70	214.20	2.98	5355.00	110.00	VPW		

Table A.1 : Design of RRWH System for All Buildings in Zone-I

3			Buil	ding Co	de & B	Roof	Tvne				A-3	: FR
	F	Plan Area		<u></u>	2549.		Effective Area A _{eff} (r			A." (m		2549.00
			Potential (k	1)	1261.		Total Discharge from Rooftop (LF					35.40
	,		· · ·	/			Collection System on Wall/Roof					
	From	То	L (m)		CA (m ²)		Q (LPS)		Size (mm ²)		Dia (mm)	TYPE
	1	2	31.50		312.90		4.35	/	15645.00		160.00	HPW
	2	3	31.50		625.80		8.69		31290.00		225.00	HPW
	3	IC-3	9.70		8.70		13.04		23467.50		200.00	VPW
	4	5	20.00		5.76		3.00		10788.00		140.00	HPW
	5	6	22.10		1.52		5.99		21576.00		180.00	HPW
	7	8	26.40	31	6.63		4.40		15831.25		160.00	HPW
	8	6	26.40	63	3.25		8.80		31662.50		225.00	HPW
	6	IC-4	9.70		64.77		14.79	9	26619.25		200.00	VP
	9	10	20.00		5.76		3.00		10788.00		140.00	HPW
	10	11	22.10		1.52		5.99		21576.00		180.00	HPW
	11	IC-7	9.70		31.52		5.99		10788.00		140.00	VPW
4				ding Co		loof						: FR
		Plan Area	A (m²)		636.0				Effective Area			636.00
	Annua	l RRWH F	Potential (k	iL)	314.7	78	Tot	al Di	scharge from	Rooft	op (LPS)	8.83
			Ē	esign o	f Rainw	vater	Collect	ion S	System on Wal	I/Root		
	From	То	L (m)		۸ (m²)		Q (LPS		Size (mm ²)	Dia (mm)	TYPE
	1	2	26.50	13	84.68		1.87		6734.00		110.00	HPW
	2	4	24.00	26	9.36		3.74		13468.00		140.00	HPW
	3	4	26.50	13	84.68		1.87		6734.00		110.00	HPW
	4	IC-6	3.40		636.00		7.48		15900.00		140.00	VPW
5				ng Code			pe				DE-14	
		Plan Area A (m ²) 581.10						Effective Area			581.10	
	Annua	ll RRWH F	otential (k		287.6				scharge from			8.07
		1							System on Wal	I/Root		
	From	То	L (m)	CA (Q (LPS)		Size (mm²)		Dia (mm)	TYPE
	1	2	14.90	193		2.69			9685.00		125.00	HPW
	2	3	14.90	387			5.38		19370.00		180.00	HPW
	3	4	14.90	581			8.07		29055.00		225.00	HPW
	4	IC-5	3.40	581			8.07		14527.50		160.00	VPW
6			Buildin	g Code			уре				<u>BC-1 :</u>	
		Plan Area			106.3				Effective Area			106.32
	Annua	u KKWH F	Potential (k	,	52.6				scharge from			1.48
$\left - \right $	F	-							System on Wal			
	From	То	L (m)		1 ²)			5	Size (mm ²)		Dia (mm)	TYPE
$\left \right $	1	2	5.30	53.1			.74		2658.00		75.00	HPW
	2	3	5.30	106.3			.48		5316.00		90.00	HPW
	3	IC-8	6.40	106.3			.48		2658.00		75.00	VPW
7			Buildin	g Code			ype				BC-2-1	
		Plan Area			468.5				Effective Area			468.58
	Annua	I RRWH F	Potential (k		231.9				scharge from			6.51
		_							System on Wal	I/Root		
	From	То	L (m)	CA (r		,	LPS)	S	Size (mm²)		Dia (mm)	TYPE
	1	2	19.50				.63		5861.00		110.00	HPW
\mid	2	6	19.50	234.			.26		11722.00		140.00	HPW
\mid	3	4	14.00	78.1			.09		3907.00		90.00	HPW
	4	5	14.00	156.			.17		7814.00		110.00	HPW
	5	6	14.00	234.			.26		11721.00		140.00	HPW
	6	IC-9	9.80	468.	58	6	.51		11714.38		140.00	VPW

SR - Sloping Roof, HG-Horizontal Gutter, VP - Vertical Pipe, HPW - Horizontal Pipe on Wall ٠

Pitch of Roof (Degree) = 26-35, Area Correction Factor = 1.2, Rainfall Intensity - 50 mm/hour •

External Gutter Size per unit of Drainage Area - 50 mm²/m², •

Horizontal Down Pipe Size per unit of Drainage Area $~(<15^{\circ}\,Slope)\text{-}\,50\,\,mm^2/m^2$ •

Vertical Down Pipe Size per unit of Drainage Area - 25 mm²/m² •

© 2013 Global Journals Inc. (US)

Points	Chainage	GRL	Q-ADD at Intake Chamber	LENGTH	Q- PIPE	DROP	SL- Available (X)	Pipe Dia				
	m	m	LPS	m	LPS		1 : X	mm				
MAIN LINE	MAIN LINE-1											
IC-1	0.00	263.285	3.08									
				60.00	3.08	0.680	88.24	100.00				
IC-2	60.00	262.605	2.98									
				14.00	6.06	0.715	19.58	100.00				
IC-3	74.00	261.890	13.04									
				56.00	19.09	0.500	112.00	150.00				
IC-4	130.00	261.390	14.79									
				7.00	33.88	0.095	73.68	200.00				
IC-5	137.00	261.295	8.07									
				71.00	41.95	0.345	205.80	250.00				
IC-7	208.00	260.950	13.47									
				26.00	55.42	0.495	52.53	250.00				
IC-8	234.00	260.455	1.48									
				39.00	56.90	0.080	487.50	300.00				
GWRS-I	273.00	260.375										
BRANCH L	LINE											
IC-6	0.00	262.055	7.48									
				35.00	7.48	1.105	31.67	100.00				
IC-7	35.00	260.950	5.99									
					13.47							
MAIN LINE	- 2											
IC-9	0.00	260.975	6.59									
				25.00	6.59	0.600	41.67	100.00				
GWRS-I	25.00	260.375										

Table A.2 : Design c	f Lindoraround Dinc	Ling for Zong L
TADIE A.Z. Desiun c	יו טווטפוטוטעווט דוטנ	

Table A.3 : Abstract of Estimate RWHS for Zone-I

Sr	Description of Items	Unit	Qty	Rate (Rs/Unit)	Cost (Rs)
1	PVC Pipe + Jointing				
	75 mm	RMT	11.70	110.00	1287.00
	90 mm	RMT	19.30	154.00	2972.20
	110 mm	RMT	120.70	224.00	27036.80
	125 mm	RMT	14.90	304.00	4529.60
	140 mm	RMT	120.00	382.00	45840.00
	160 mm	RMT	92.80	496.00	46028.80
	180 mm	RMT	59.10	625.00	36937.50
	200 mm	RMT	19.40	733.00	14220.20
	225 mm	RMT	41.30	945.00	39028.50
	160 mm	RMT	60.00	345.60	20736.00
2	RCC Pipe below GL				
	100 mm	RMT	134.00	284.00	38056.00
	150 mm	RMT	56.00	468.00	26208.00
	200 mm	RMT	7.00	636.00	4452.00
	250 mm	RMT	97.00	887.00	86039.00
	300 mm	RMT	39.00	1231.00	48009.00
3	Pipe Minor Fittings - Material	10% c	of Cost of I	Pipes	21788.06
4	Pipe Fixing in Wall - Labour	20% c	of Cost of I	Pipes	43576.12
5	Gutters Minor Fittings - Material	10% c	of Cost of	Gutters	2073.60
6	Gutter Fixing in Roof - Labour	20% c	of Cost of	Gutters	4147.20
7	Lowering & Laying - RCC Pipes				
	100 mm	RMT	134.00	31.00	4154.00
	150 mm	RMT	56.00	45.00	2520.00
	200 mm	RMT	7.00	59.00	413.00

-	050		07.00		7000.00				
	250 mm	RMT	97.00		7663.00				
	300 mm	RMT	39.00	96.00	3744.00				
8	Excavation & Refilling								
	Soft Murum (0.60 x 0.30 m)	Cum	59.94	4 114.00	6833.16				
	Hard Murum (0.60 x 0.20 m)	Cum	39.96	6 127.00	5074.92				
9	Intake Chamber								
	Intake Pipe 1.0 m	No	3	1207.00	3621.00				
	Intake Pipe 1.5 m	No	3	1559.00	4677.00				
	Intake Pipe 2.0 m	No	3	1911.00	5733.00				
10	Chamber with Vent Pipe	No	11	620.00	6820.00				
11	GWRS (Open Dug Well with Bore)	No	1	497450.00	528250.00				
Gro	ss Cost- Rs.				1061668.66				
Cos	Cost in Building-Rs.								
Cos	t in Conveyance Below Ground-Rs.				223217.08				
Cos	t of GWRS-Rs.				528250.00				
Ann	ual Quantity of RRWH-kL				2364.35				
Life	of Project -Years	40)	Rate of Interest -	0.04				
Equ	ivalent Annual Cost Factor				0.0505				
Equ	Equivalent Annual Capital Cost with GWRS -Rs.								
Equ	26950.17								
Cap	22.69								
Cap	11.40								
Cap	56.72								
Cap	Capital Cost/kL (considering 40% utilizable) - Rs/kL- Capital Cost/kL (without GWRS) (considering 40% utilizable) - Rs/kL-								